

ANALYTICAL REPORT

Job Number: 420-193887-1

SDG Number: Warwick VCSD- Kings School

Job Description: Orange-Ulster BOCES

For:

Orange-Ulster BOCES

53 Gibson Road

Goshen, NY 10924

Attention: Jack DeGraw

Meredith Ruthven

Meredith W Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

05/03/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at envirotestlabs/terms.com. As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

Envirotest Laboratories

315 Fullerton Avenue, Newburgh, NY 12550

Tel (845) 562-0890 Fax (845) 562-0841 www.envirotestlaboratories.com

METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193887-1
SDG Number: Warwick VCSD- Kings School

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193887-1
SDG Number: Warwick VCSD- Kings School

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Luis, Carlos	CL

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193887-1
SDG Number: Warwick VCSD- Kings School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-193887-1	Kitchen HWS	Drinking Water	03/25/2021 0601	03/26/2021 1120
420-193887-2	Kitchen KS 1	Drinking Water	03/25/2021 0602	03/26/2021 1120
420-193887-3	Kitchen KS 2	Drinking Water	03/25/2021 0602	03/26/2021 1120
420-193887-4	Kitchen HWS by Refrigerator	Drinking Water	03/25/2021 0603	03/26/2021 1120
420-193887-5	Kitchen Single Sink	Drinking Water	03/25/2021 0603	03/26/2021 1120
420-193887-6	Family Room BS	Drinking Water	03/25/2021 0604	03/26/2021 1120
420-193887-7	Secondary Office BS	Drinking Water	03/25/2021 0605	03/26/2021 1120
420-193887-8	Office Hallway BS	Drinking Water	03/25/2021 0605	03/26/2021 1120
420-193887-9	Main Office BS	Drinking Water	03/25/2021 0606	03/26/2021 1120
420-193887-10	Main Office KS	Drinking Water	03/25/2021 0606	03/26/2021 1120
420-193887-11	Handicapped BS	Drinking Water	03/25/2021 0608	03/26/2021 1120
420-193887-12	Main Hallway WC	Drinking Water	03/25/2021 0609	03/26/2021 1120
420-193887-13	202 CS	Drinking Water	03/25/2021 0611	03/26/2021 1120
420-193887-14	204 CS	Drinking Water	03/25/2021 0612	03/26/2021 1120
420-193887-15	205 CS	Drinking Water	03/25/2021 0613	03/26/2021 1120
420-193887-16	206 KS	Drinking Water	03/25/2021 0614	03/26/2021 1120
420-193887-17	207 CS	Drinking Water	03/25/2021 0615	03/26/2021 1120
420-193887-18	208 CS	Drinking Water	03/25/2021 0616	03/26/2021 1120
420-193887-19	209 CS	Drinking Water	03/25/2021 0616	03/26/2021 1120
420-193887-20	210 CS	Drinking Water	03/25/2021 0617	03/26/2021 1120
420-193887-21	211 CS	Drinking Water	03/25/2021 0618	03/26/2021 1120
420-193887-22	201 CS	Drinking Water	03/25/2021 0620	03/26/2021 1120
420-193887-23	200 Wing Girls BS 1	Drinking Water	03/25/2021 0622	03/26/2021 1120
420-193887-24	200 Wing Girls BS 2	Drinking Water	03/25/2021 0622	03/26/2021 1120
420-193887-25	200 Wing Girls BS 3	Drinking Water	03/25/2021 0622	03/26/2021 1120
420-193887-26	200 Wing Boys BS 1	Drinking Water	03/25/2021 0623	03/26/2021 1120
420-193887-27	200 Wing Boys BS 2	Drinking Water	03/25/2021 0623	03/26/2021 1120
420-193887-28	200 Wing Boys BS 3	Drinking Water	03/25/2021 0623	03/26/2021 1120
420-193887-29	Lower Wing Faculty BS	Drinking Water	03/25/2021 0626	03/26/2021 1120
420-193887-30	Lower Wing Boys BS 1	Drinking Water	03/25/2021 0627	03/26/2021 1120
420-193887-31	Lower Wing Boys BS 2	Drinking Water	03/25/2021 0627	03/26/2021 1120
420-193887-32	Lower Wing Boys BS 3	Drinking Water	03/25/2021 0627	03/26/2021 1120
420-193887-33	Lower Wing Girls BS 1	Drinking Water	03/25/2021 0629	03/26/2021 1120
420-193887-34	Lower Wing Girls BS 2	Drinking Water	03/25/2021 0629	03/26/2021 1120
420-193887-35	Lower Wing Girls BS 3	Drinking Water	03/25/2021 0629	03/26/2021 1120
420-193887-36	101 KS	Drinking Water	03/25/2021 0631	03/26/2021 1120
420-193887-37	102 KS	Drinking Water	03/25/2021 0633	03/26/2021 1120
420-193887-38	103 KS	Drinking Water	03/25/2021 0634	03/26/2021 1120
420-193887-39	104 KS	Drinking Water	03/25/2021 0635	03/26/2021 1120
420-193887-40	105 KS	Drinking Water	03/25/2021 0637	03/26/2021 1120
420-193887-41	106 KS	Drinking Water	03/25/2021 0638	03/26/2021 1120
420-193887-42	107 KS	Drinking Water	03/25/2021 0640	03/26/2021 1120
420-193887-43	108 KS	Drinking Water	03/25/2021 0641	03/26/2021 1120
420-193887-44	109 KS	Drinking Water	03/25/2021 0642	03/26/2021 1120
420-193887-45	110 KS	Drinking Water	03/25/2021 0643	03/26/2021 1120

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193887-1
SDG Number: Warwick VCSD- Kings School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-193887-46	Libary CS	Drinking Water	03/25/2021 0650	03/26/2021 1120
420-193887-47	Bubbler O/S Phone Booth	Drinking Water	03/25/2021 0652	03/26/2021 1120
420-193887-48	301 BS	Drinking Water	03/25/2021 0653	03/26/2021 1120
420-193887-49	Bubbler O/S 301	Drinking Water	03/25/2021 0655	03/26/2021 1120
420-193887-50	302 BS	Drinking Water	03/25/2021 0655	03/26/2021 1120
420-193887-51	303 BS	Drinking Water	03/25/2021 0656	03/26/2021 1120
420-193887-52	Bubbler O/S 303	Drinking Water	03/25/2021 0658	03/26/2021 1120
420-193887-53	304 BS	Drinking Water	03/25/2021 0659	03/26/2021 1120
420-193887-54	Coach's Office BS	Drinking Water	03/25/2021 0700	03/26/2021 1120
420-193887-55	305 CS	Drinking Water	03/25/2021 0702	03/26/2021 1120
420-193887-56	306 CS	Drinking Water	03/25/2021 0703	03/26/2021 1120
420-193887-57	O/S 307 Lower WC	Drinking Water	03/25/2021 0704	03/26/2021 1120
420-193887-58	O/S 307 High WC	Drinking Water	03/25/2021 0704	03/26/2021 1120
420-193887-59	307 CS	Drinking Water	03/25/2021 0706	03/26/2021 1120
420-193887-60	308 CS	Drinking Water	03/25/2021 0707	03/26/2021 1120
420-193887-61	309 CS	Drinking Water	03/25/2021 0708	03/26/2021 1120
420-193887-62	311 CS	Drinking Water	03/25/2021 0709	03/26/2021 1120
420-193887-63	310 CS	Drinking Water	03/25/2021 0710	03/26/2021 1120
420-193887-64	312 CS	Drinking Water	03/25/2021 0710	03/26/2021 1120
420-193887-65	200 Wing Left Bubbler	Drinking Water	03/25/2021 0713	03/26/2021 1120
420-193887-66	200 Wing Right Bubbler	Drinking Water	03/25/2021 0713	03/26/2021 1120
420-193887-67	Lower Wing Left Bubbler	Drinking Water	03/25/2021 0716	03/26/2021 1120
420-193887-68	Lower Wing Center Bubbler	Drinking Water	03/25/2021 0716	03/26/2021 1120
420-193887-69	Lower Wing Right Bubbler	Drinking Water	03/25/2021 0716	03/26/2021 1120

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Kitchen HWS
Lab Sample ID: 420-193887-1

Date Sampled: 03/25/2021 0601
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/21/2021	1956	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	15.9 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Kitchen KS 1
Lab Sample ID: 420-193887-2

Date Sampled: 03/25/2021 0602
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/21/2021 2002	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Kitchen KS 2
Lab Sample ID: 420-193887-3

Date Sampled: 03/25/2021 0602
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/27/2021 1848	
Prep Method: 200.7/200.8			Date Prepared:	04/22/2021 1720	
Pb	9.62	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Kitchen HWS by Refrigerator
Lab Sample ID: 420-193887-4

Date Sampled: 03/25/2021 0603
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/21/2021 2005	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	10.3	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Kitchen Single Sink
Lab Sample ID: 420-193887-5

Date Sampled: 03/25/2021 0603
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/21/2021 2008	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	1.18	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Family Room BS
Lab Sample ID: 420-193887-6

Date Sampled: 03/25/2021 0604
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/21/2021	2011	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	28.9 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Secondary Office BS
Lab Sample ID: 420-193887-7

Date Sampled: 03/25/2021 0605
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	1426	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	129 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Office Hallway BS
Lab Sample ID: 420-193887-8

Date Sampled: 03/25/2021 0605
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021 1429		
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021 0930		
Pb	12.2	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Main Office BS
Lab Sample ID: 420-193887-9

Date Sampled: 03/25/2021 0606
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	1438	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	13.3	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Main Office KS
Lab Sample ID: 420-193887-10

Date Sampled: 03/25/2021 0606
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	1441	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	20.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Handicapped BS
Lab Sample ID: 420-193887-11

Date Sampled: 03/25/2021 0608
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	1444	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	7.57	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Main Hallway WC
Lab Sample ID: 420-193887-12

Date Sampled: 03/25/2021 0609
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	1456	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	2.22	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 202 CS
Lab Sample ID: 420-193887-13

Date Sampled: 03/25/2021 0611
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021 1459		
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021 0930		
Pb	19.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 204 CS
Lab Sample ID: 420-193887-14

Date Sampled: 03/25/2021 0612
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 1502	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	4.01	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 205 CS
Lab Sample ID: 420-193887-15

Date Sampled: 03/25/2021 0613
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	1506	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	42.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 206 KS
Lab Sample ID: 420-193887-16

Date Sampled: 03/25/2021 0614
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 1515	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	20.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 207 CS
Lab Sample ID: 420-193887-17

Date Sampled: 03/25/2021 0615
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 1518	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	25.1 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 208 CS
Lab Sample ID: 420-193887-18

Date Sampled: 03/25/2021 0616
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021 1521		
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021 0930		
Pb	3.77	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 209 CS
Lab Sample ID: 420-193887-19

Date Sampled: 03/25/2021 0616
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 1524	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	7.27	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 210 CS
Lab Sample ID: 420-193887-20

Date Sampled: 03/25/2021 0617
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	1527	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	14.3	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 211 CS
Lab Sample ID: 420-193887-21

Date Sampled: 03/25/2021 0618
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021 1530		
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021 0930		
Pb	10.3	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 201 CS
Lab Sample ID: 420-193887-22

Date Sampled: 03/25/2021 0620
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	1536	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	44.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 200 Wing Girls BS 1
Lab Sample ID: 420-193887-23

Date Sampled: 03/25/2021 0622
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 1539	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	5.77	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 200 Wing Girls BS 2
Lab Sample ID: 420-193887-24

Date Sampled: 03/25/2021 0622
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 1542	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	2.78	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 200 Wing Girls BS 3
Lab Sample ID: 420-193887-25

Date Sampled: 03/25/2021 0622
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	1551	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	2.09	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 200 Wing Boys BS 1
Lab Sample ID: 420-193887-26

Date Sampled: 03/25/2021 0623
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 1554	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	2.03	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 200 Wing Boys BS 2
Lab Sample ID: 420-193887-27

Date Sampled: 03/25/2021 0623
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021 1557		
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021 0930		
Pb	1.20	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 200 Wing Boys BS 3
Lab Sample ID: 420-193887-28

Date Sampled: 03/25/2021 0623
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 1600	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	3.96	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Lower Wing Faculty BS
Lab Sample ID: 420-193887-29

Date Sampled: 03/25/2021 0626
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 1603	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	1.21	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Lower Wing Boys BS 1
Lab Sample ID: 420-193887-30

Date Sampled: 03/25/2021 0627
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	1606	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	6.34	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Lower Wing Boys BS 2
Lab Sample ID: 420-193887-31

Date Sampled: 03/25/2021 0627
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 1609	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	11.7	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Lower Wing Boys BS 3
Lab Sample ID: 420-193887-32

Date Sampled: 03/25/2021 0627
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	1941	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	16.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Lower Wing Girls BS 1
Lab Sample ID: 420-193887-33

Date Sampled: 03/25/2021 0629
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 1943	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	26.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Lower Wing Girls BS 2
Lab Sample ID: 420-193887-34

Date Sampled: 03/25/2021 0629
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	1946	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	18.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Lower Wing Girls BS 3
Lab Sample ID: 420-193887-35

Date Sampled: 03/25/2021 0629
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 1948	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	8.61	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 101 KS
Lab Sample ID: 420-193887-36

Date Sampled: 03/25/2021 0631
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 1950	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	9.73	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 102 KS
Lab Sample ID: 420-193887-37

Date Sampled: 03/25/2021 0633
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 1952	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	11.8	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 103 KS
Lab Sample ID: 420-193887-38

Date Sampled: 03/25/2021 0634
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	1954	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	4.68	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 104 KS
Lab Sample ID: 420-193887-39

Date Sampled: 03/25/2021 0635
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 1957	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	28.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 105 KS
Lab Sample ID: 420-193887-40

Date Sampled: 03/25/2021 0637
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	2003	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	489 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 106 KS
Lab Sample ID: 420-193887-41

Date Sampled: 03/25/2021 0638
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	2005	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	12.4	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 107 KS
Lab Sample ID: 420-193887-42

Date Sampled: 03/25/2021 0640
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	2010	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	19.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 108 KS
Lab Sample ID: 420-193887-43

Date Sampled: 03/25/2021 0641
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	2012	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	27.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 109 KS
Lab Sample ID: 420-193887-44

Date Sampled: 03/25/2021 0642
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	2014	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	17.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 110 KS
Lab Sample ID: 420-193887-45

Date Sampled: 03/25/2021 0643
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	2016	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	52.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Library CS
Lab Sample ID: 420-193887-46

Date Sampled: 03/25/2021 0650
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	2018	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	65.1 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Bubbler O/S Phone Booth
Lab Sample ID: 420-193887-47

Date Sampled: 03/25/2021 0652
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	2021	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	26.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 301 BS
Lab Sample ID: 420-193887-48

Date Sampled: 03/25/2021 0653
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021	2023
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021	0930
Pb	28.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Bubblers O/S 301
Lab Sample ID: 420-193887-49

Date Sampled: 03/25/2021 0655
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	2029	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	13.0	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 302 BS
Lab Sample ID: 420-193887-50

Date Sampled: 03/25/2021 0655
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/27/2021	1852	
Prep Method: 200.7/200.8			Date Prepared: 04/22/2021	1720	
Pb	21.6 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 303 BS
Lab Sample ID: 420-193887-51

Date Sampled: 03/25/2021 0656
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	2031	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	51.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Bubblers O/S 303
Lab Sample ID: 420-193887-52

Date Sampled: 03/25/2021 0658
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 2040	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	11.6	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 304 BS
Lab Sample ID: 420-193887-53

Date Sampled: 03/25/2021 0659
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	2042	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	17.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Coach's Office BS
Lab Sample ID: 420-193887-54

Date Sampled: 03/25/2021 0700
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021 2045		
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021 0930		
Pb	21.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 305 CS
Lab Sample ID: 420-193887-55

Date Sampled: 03/25/2021 0702
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 2047	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	2.80	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 306 CS
Lab Sample ID: 420-193887-56

Date Sampled: 03/25/2021 0703
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 2049	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	2.53	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: O/S 307 Lower WC
Lab Sample ID: 420-193887-57

Date Sampled: 03/25/2021 0704
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021 2055		
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021 0930		
Pb	2.56	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: O/S 307 High WC
Lab Sample ID: 420-193887-58

Date Sampled: 03/25/2021 0704
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 2058	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	3.43	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 307 CS
Lab Sample ID: 420-193887-59

Date Sampled: 03/25/2021 0706
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	2100	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	15.3 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 308 CS
Lab Sample ID: 420-193887-60

Date Sampled: 03/25/2021 0707
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 2102	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	22.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 309 CS
Lab Sample ID: 420-193887-61

Date Sampled: 03/25/2021 0708
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/27/2021 1855		
Prep Method: 200.7/200.8			Date Prepared: 04/22/2021 1720		
Pb	2.62	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 311 CS
Lab Sample ID: 420-193887-62

Date Sampled: 03/25/2021 0709
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 2104	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	9.48	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 310 CS
Lab Sample ID: 420-193887-63

Date Sampled: 03/25/2021 0710
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	2109	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	1.34	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 312 CS
Lab Sample ID: 420-193887-64

Date Sampled: 03/25/2021 0710
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	2111	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	22.1 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 200 Wing Left Bubbler
Lab Sample ID: 420-193887-65

Date Sampled: 03/25/2021 0713
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/22/2021 2113	
Prep Method: 200.7/200.8			Date Prepared:	04/16/2021 0930	
Pb	11.3	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: 200 Wing Right Bubbler
Lab Sample ID: 420-193887-66

Date Sampled: 03/25/2021 0713
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021	2115	
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021	0930	
Pb	8.97	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Lower Wing Left Bubbler
Lab Sample ID: 420-193887-67

Date Sampled: 03/25/2021 0716
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021 2122		
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021 0930		
Pb	29.9 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Lower Wing Center Bubbler
Lab Sample ID: 420-193887-68

Date Sampled: 03/25/2021 0716
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/22/2021 2124		
Prep Method: 200.7/200.8			Date Prepared: 04/16/2021 0930		
Pb	16.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193887-1
Sdg Number: Warwick VCSD- Kings School

Client Sample ID: Lower Wing Right Bubbler
Lab Sample ID: 420-193887-69

Date Sampled: 03/25/2021 0716
Date Received: 03/26/2021 1120
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/27/2021 1949	
Prep Method: 200.7/200.8			Date Prepared:	04/21/2021 1120	
Pb	75.7	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:
Sdg Number: Warwick VCSD- Kings School

Lab Section	Qualifier	Description
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Warwick VCSD- Kings School

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Setttable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

Definitions and Glossary

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Warwick VCSD- Kings School

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

EnviroTest Laboratories, LLC

315 Fullerton Avenue
 Newburgh, NY 12550
 Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information	Sampler: J DeGraw Phone: 845-781-4887	Lab PM: E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 1938871 of 5
---------------------------	--	--	--	----------------------------

Company: Orange-Ulster BOCES Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924 Phone: 845-781-4887 Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	Due Date Requested: Standard Turn-Around TAT Requested (days): PO #: PWS #: Project #: Additional Contacts:	Analysis Requested 420-193887-B-1 Kitchen HWS Date Sampled: 3/25/2021 420-1652823	Page: Page 1 of 1 Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)
--	---	--	--

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample	Perform MS/MSD (Yes)	Chlorine Present (Yes)	Lead	Total Number of Containers	Other: D-Nitric Acid
											Upon Receipt Preservation verified: Y / N
											Special Instructions/Note:
3/25/21	6:01	Kitchen HWS		G	DW				1	1	
3/25/21	6:02	Kitchen KS 1		G	DW				1	1	
3/25/21	6:02	Kitchen KS 2		G	DW				1	1	
3/25/21	6:03	Kitchen HWS by Refrigerator		G	DW				1	1	
3/25/21	6:03	Kitchen Single Sink		G	DW				1	1	
3/25/21	6:04	Family Room BS		G	DW				1	1	
3/25/21	6:05	Secondary Office BS		G	DW				1	1	
3/25/21	6:05	Office Hallway BS		G	DW				1	1	
3/25/21	6:06	Main Office BS		G	DW				1	1	
3/25/21	6:06	Main Office KS		G	DW				1	1	
3/25/21	6:08	Handicapped BS		G	DW				1	1	
3/25/21	6:09	Main Hallway WC		G	DW				1	1	
3/25/21	6:11	202 CS		G	DW				1	1	
3/25/21	6:12	204 CS		G	DW				1	1	
3/25/21	6:13	205 CS		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle

Preservation Added Upon Receipt: Relinquished by: <i>[Signature]</i> Relinquished by: Relinquished by:	Manufacturer/Lot #: Date/Time: 3/26/21 11:20 Date/Time: Date/Time:	Company: OUBOCES Company: Company:	Received by: <i>[Signature]</i> Received by: Received by:	Sample # (s): Date/Time: 3/26/21 11:20 Date/Time: Date/Time:	Company: <i>[Signature]</i> Company: Company:
---	---	--	---	---	---

ICE Present: Custody Seal No.: _____ Custody Seals Intact: Cooler Temperature(s) °C/IR GUN #: 20.5°C

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Orange-Ulster BOCES

Job Number: 420-193887-1
SDG Number: Warwick VCSD- Kings School

Login Number: 193887

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	20.5 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	