

ANALYTICAL REPORT

Job Number: 420-193868-1
SDG Number: Warwick High School
Job Description: Orange-Ulster BOCES

For:
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Attention: Jack DeGraw

Meredith Ruthven

Meredith W Ruthven
Customer Service Manager
mruthven@envirotestlaboratories.com
04/28/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at envirotestlabs/terms.com. As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOPH PH-0554

METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193868-1
SDG Number: Warwick High School

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193868-1
SDG Number: Warwick High School

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Luis, Carlos	CL

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193868-1
SDG Number: Warwick High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-193868-1	Loading Dock BS	Drinking Water	03/23/2021 0401	03/24/2021 1041
420-193868-2	Office KS	Drinking Water	03/23/2021 0404	03/24/2021 1041
420-193868-3	Office Left BS	Drinking Water	03/23/2021 0405	03/24/2021 1041
420-193868-4	Office Right BS	Drinking Water	03/23/2021 0405	03/24/2021 1041
420-193868-5	Mens BS by Elevator	Drinking Water	03/23/2021 0406	03/24/2021 1041
420-193868-6	Ladies BS by Elevator	Drinking Water	03/23/2021 0406	03/24/2021 1041
420-193868-7	Guidance Hall Way Girls BS 1	Drinking Water	03/23/2021 0408	03/24/2021 1041
420-193868-8	Guidance Hall Way Girls BS 2	Drinking Water	03/23/2021 0408	03/24/2021 1041
420-193868-9	Guidance Hall Way Girls BS 3	Drinking Water	03/23/2021 0408	03/24/2021 1041
420-193868-10	Guidance Hall Way Boys BS 1	Drinking Water	03/23/2021 0411	03/24/2021 1041
420-193868-11	Guidance Hall Way Boys BS 2	Drinking Water	03/23/2021 0411	03/24/2021 1041
420-193868-12	Guidance Hall Way Boys BS 3	Drinking Water	03/23/2021 0411	03/24/2021 1041
420-193868-13	Guidance BS	Drinking Water	03/23/2021 0415	03/24/2021 1041
420-193868-14	Boys BS 1 Outside Old Gym	Drinking Water	03/23/2021 0417	03/24/2021 1041
420-193868-15	Boys BS 2 Outside Old Gym	Drinking Water	03/23/2021 0417	03/24/2021 1041
420-193868-16	Boys BS 3 Outside Old Gym	Drinking Water	03/23/2021 0417	03/24/2021 1041
420-193868-17	Faculty BS Outside Old Gym	Drinking Water	03/23/2021 0420	03/24/2021 1041
420-193868-18	Outside Old Gym BF	Drinking Water	03/23/2021 0420	03/24/2021 1041
420-193868-19	Outside Old Gym Girls BS 1	Drinking Water	03/23/2021 0421	03/24/2021 1041
420-193868-20	Outside Old Gym Girls BS 2	Drinking Water	03/23/2021 0421	03/24/2021 1041
420-193868-21	Outside Old Gym Girls BS 3	Drinking Water	03/23/2021 0421	03/24/2021 1041
420-193868-22	Boys Room by 118 BS 1	Drinking Water	03/23/2021 0425	03/24/2021 1041
420-193868-23	Boys Room by 118 BS 2	Drinking Water	03/23/2021 0425	03/24/2021 1041
420-193868-24	BF by 118	Drinking Water	03/23/2021 0425	03/24/2021 1041
420-193868-25	Faculty BS by 118	Drinking Water	03/23/2021 0426	03/24/2021 1041
420-193868-26	Girls Room by 118 BS 1	Drinking Water	03/23/2021 0428	03/24/2021 1041
420-193868-27	Girls Room by 118 BS 2	Drinking Water	03/23/2021 0428	03/24/2021 1041
420-193868-28	Nurse BS	Drinking Water	03/23/2021 0431	03/24/2021 1041
420-193868-29	Nurse NS	Drinking Water	03/23/2021 0431	03/24/2021 1041
420-193868-30	Nurse KS	Drinking Water	03/23/2021 0431	03/24/2021 1041
420-193868-31	Stage Left BS	Drinking Water	03/23/2021 0435	03/24/2021 1041
420-193868-32	Stage BF	Drinking Water	03/23/2021 0435	03/24/2021 1041
420-193868-33	Stage Right BS	Drinking Water	03/23/2021 0435	03/24/2021 1041
420-193868-34	Band Room CS	Drinking Water	03/23/2021 0428	03/24/2021 1041
420-193868-35	South Cafeteria BF	Drinking Water	03/23/2021 0439	03/24/2021 1041
420-193868-36	Serving Area HWS	Drinking Water	03/23/2021 0440	03/24/2021 1041
420-193868-37	Serving Area Prep Sink	Drinking Water	03/23/2021 0440	03/24/2021 1041

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193868-1
SDG Number: Warwick High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-193868-38	Kitchen Prep Sink	Drinking Water	03/23/2021 0442	03/24/2021 1041
420-193868-39	Dishwasher Room Sink 1	Drinking Water	03/23/2021 0443	03/24/2021 1041
420-193868-40	Dishwasher Room Sink 2	Drinking Water	03/23/2021 0443	03/24/2021 1041
420-193868-41	Dishwasher Room Sink 3	Drinking Water	03/23/2021 0443	03/24/2021 1041
420-193868-42	Kitchen Pot Filler	Drinking Water	03/23/2021 0445	03/24/2021 1041
420-193868-43	Kitchen HWS	Drinking Water	03/23/2021 0445	03/24/2021 1041
420-193868-44	Kitchen Single Sink	Drinking Water	03/23/2021 0446	03/24/2021 1041
420-193868-45	Kitchen KS 1	Drinking Water	03/23/2021 0447	03/24/2021 1041
420-193868-46	Kitchen KS 2	Drinking Water	03/23/2021 0447	03/24/2021 1041
420-193868-47	Kitchen Left BS	Drinking Water	03/23/2021 0448	03/24/2021 1041
420-193868-48	Kitchen Right BS	Drinking Water	03/23/2021 0448	03/24/2021 1041
420-193868-49	North Cafe BF	Drinking Water	03/23/2021 0451	03/24/2021 1041
420-193868-50	New Gym Boys BS 1	Drinking Water	03/23/2021 0453	03/24/2021 1041
420-193868-51	New Gym Boys BS 2	Drinking Water	03/23/2021 0453	03/24/2021 1041
420-193868-52	New Gym Boys BS 3	Drinking Water	03/23/2021 0453	03/24/2021 1041
420-193868-53	New Gym Girls BS 1	Drinking Water	03/23/2021 0455	03/24/2021 1041
420-193868-54	New Gym Girls BS 2	Drinking Water	03/23/2021 0455	03/24/2021 1041
420-193868-55	New Gym Girls BS 3	Drinking Water	03/23/2021 0455	03/24/2021 1041
420-193868-56	Phys Ed Office BS	Drinking Water	03/23/2021 0458	03/24/2021 1041
420-193868-57	Training Room CS	Drinking Water	03/23/2021 0500	03/24/2021 1041
420-193868-58	Training Room Hose	Drinking Water	03/23/2021 0500	03/24/2021 1041
420-193868-59	New Gym Boys Locker Room BS 1	Drinking Water	03/23/2021 0502	03/24/2021 1041
420-193868-60	New Gym Boys Locker Room BS 3	Drinking Water	03/23/2021 0502	03/24/2021 1041
420-193868-61	New Gym Mens Coaches BS	Drinking Water	03/23/2021 0503	03/24/2021 1041
420-193868-62	New Gym BF	Drinking Water	03/23/2021 0504	03/24/2021 1041
420-193868-63	New Gym Womens Coaches BS	Drinking Water	03/23/2021 0505	03/24/2021 1041
420-193868-64	New Gym Girls Locker Room BS 3	Drinking Water	03/23/2021 0505	03/24/2021 1041
420-193868-65	Athletic Director KS	Drinking Water	03/23/2021 0508	03/24/2021 1041
420-193868-66	By 165 Mens BS 1	Drinking Water	03/23/2021 0511	03/24/2021 1041
420-193868-67	By 165 Mens BS 2	Drinking Water	03/23/2021 0511	03/24/2021 1041
420-193868-68	By 165 Girls BS 1	Drinking Water	03/23/2021 0513	03/24/2021 1041
420-193868-69	By 165 Girls BS	Drinking Water	03/23/2021 0513	03/24/2021 1041
420-193868-70	By 165 DF	Drinking Water	03/23/2021 0513	03/24/2021 1041
420-193868-71	164 CS	Drinking Water	03/23/2021 0514	03/24/2021 1041
420-193868-72	Womens Faculty BS by 163	Drinking Water	03/23/2021 0516	03/24/2021 1041
420-193868-73	Mens Faculty BS by 163	Drinking Water	03/23/2021 0516	03/24/2021 1041
420-193868-74	By 65 Boys BS 1	Drinking Water	03/23/2021 0519	03/24/2021 1041
420-193868-75	By 65 Boys BS 2	Drinking Water	03/23/2021 0519	03/24/2021 1041
420-193868-76	By 65 Girls BS 1	Drinking Water	03/23/2021 0521	03/24/2021 1041
420-193868-77	By 65 Girls BS 2	Drinking Water	03/23/2021 0521	03/24/2021 1041
420-193868-78	By 65 BF	Drinking Water	03/23/2021 0522	03/24/2021 1041
420-193868-79	Special Ed CS	Drinking Water	03/23/2021 0526	03/24/2021 1041

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-193868-1
SDG Number: Warwick High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-193868-80	Faculty Room KS	Drinking Water	03/23/2021 0526	03/24/2021 1041
420-193868-81	Faculty Utility Sink	Drinking Water	03/23/2021 0528	03/24/2021 1041
420-193868-82	Faculty Room Womans BS	Drinking Water	03/23/2021 0528	03/24/2021 1041
420-193868-83	Faculty Room Mens BS	Drinking Water	03/23/2021 0528	03/24/2021 1041
420-193868-84	Boys Old Gym Locker Room BS	Drinking Water	03/23/2021 0531	03/24/2021 1041
420-193868-85	Boys Swim Coach BS	Drinking Water	03/23/2021 0533	03/24/2021 1041
420-193868-86	Boys Swim Locker Room BS	Drinking Water	03/23/2021 0534	03/24/2021 1041
420-193868-87	Girls Swim Locker Room BS	Drinking Water	03/23/2021 0535	03/24/2021 1041
420-193868-88	Girls Swim Coach BS	Drinking Water	03/23/2021 0537	03/24/2021 1041
420-193868-89	Girls Old Gym Locker Room BS	Drinking Water	03/23/2021 0538	03/24/2021 1041
420-193868-90	Library KS	Drinking Water	03/23/2021 0541	03/24/2021 1041
420-193868-91	BF by 142	Drinking Water	03/23/2021 0543	03/24/2021 1041
420-193868-92	143 CS	Drinking Water	03/23/2021 0544	03/24/2021 1041
420-193868-93	Ag Shop CS 1	Drinking Water	03/23/2021 0545	03/24/2021 1041
420-193868-94	Ag Shop CS 2	Drinking Water	03/23/2021 0545	03/24/2021 1041
420-193868-95	Ag Shop Single Sink	Drinking Water	03/23/2021 0545	03/24/2021 1041
420-193868-96	Custodial Break Room KS	Drinking Water	03/23/2021 0548	03/24/2021 1041
420-193868-97	Mens BS by 138	Drinking Water	03/23/2021 0550	03/24/2021 1041
420-193868-98	Womans BS 1 by 138	Drinking Water	03/23/2021 0550	03/24/2021 1041
420-193868-99	Womans BS 2 by 138	Drinking Water	03/23/2021 0550	03/24/2021 1041
420-193868-100	Conference Room KS	Drinking Water	03/23/2021 0554	03/24/2021 1041
420-193868-101	Girls BS 1 by 234	Drinking Water	03/23/2021 0557	03/24/2021 1041
420-193868-102	Girls BS 2 by 234	Drinking Water	03/23/2021 0557	03/24/2021 1041
420-193868-103	Girls BS 3 by 234	Drinking Water	03/23/2021 0557	03/24/2021 1041
420-193868-104	Boys BS 1 by 234	Drinking Water	03/23/2021 0559	03/24/2021 1041
420-193868-105	Boys BS 2 by 234	Drinking Water	03/23/2021 0559	03/24/2021 1041
420-193868-106	Boys BS 3 by 234	Drinking Water	03/23/2021 0559	03/24/2021 1041
420-193868-107	Faculty BS by 236A	Drinking Water	03/23/2021 0602	03/24/2021 1041
420-193868-108	Boys BS by 218	Drinking Water	03/23/2021 0606	03/24/2021 1041
420-193868-109	Faculty BS by 218	Drinking Water	03/23/2021 0606	03/24/2021 1041
420-193868-110	BF by 218	Drinking Water	03/23/2021 0607	03/24/2021 1041
420-193868-111	Girls BS 1 by 218	Drinking Water	03/23/2021 0608	03/24/2021 1041
420-193868-112	Girls BS 2 by 218	Drinking Water	03/23/2021 0608	03/24/2021 1041

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Loading Dock BS
Lab Sample ID: 420-193868-1

Date Sampled: 03/23/2021 0401
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0443		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Office KS
Lab Sample ID: 420-193868-2

Date Sampled: 03/23/2021 0404
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0452	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	10.5	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Office Left BS
Lab Sample ID: 420-193868-3

Date Sampled: 03/23/2021 0405
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0454		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Office Right BS
Lab Sample ID: 420-193868-4

Date Sampled: 03/23/2021 0405
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021	0456	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	0830	
Pb	2.09	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Mens BS by Elevator
Lab Sample ID: 420-193868-5

Date Sampled: 03/23/2021 0406
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0503		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Ladies BS by Elevator
Lab Sample ID: 420-193868-6

Date Sampled: 03/23/2021 0406
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0505	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	4.10	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Guidance Hall Way Girls BS 1
Lab Sample ID: 420-193868-7

Date Sampled: 03/23/2021 0408
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0507	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	74.0	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Guidance Hall Way Girls BS 2
Lab Sample ID: 420-193868-8

Date Sampled: 03/23/2021 0408
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0509		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	43.3	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Guidance Hall Way Girls BS 3
Lab Sample ID: 420-193868-9

Date Sampled: 03/23/2021 0408
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0511	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	43.5	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Guidance Hall Way Boys BS 1
Lab Sample ID: 420-193868-10

Date Sampled: 03/23/2021 0411
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021	2158	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	1538	
Pb	10.8	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Guidance Hall Way Boys BS 2
Lab Sample ID: 420-193868-11

Date Sampled: 03/23/2021 0411
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0513	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	27.0	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Guidance Hall Way Boys BS 3
Lab Sample ID: 420-193868-12

Date Sampled: 03/23/2021 0411
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0518	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	6.39	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Guidance BS
Lab Sample ID: 420-193868-13

Date Sampled: 03/23/2021 0415
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0520		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Boys BS 1 Outside Old Gym
Lab Sample ID: 420-193868-14

Date Sampled: 03/23/2021 0417
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0522		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Boys BS 2 Outside Old Gym
Lab Sample ID: 420-193868-15

Date Sampled: 03/23/2021 0417
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021	2216	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	1538	
Pb	7.77	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Boys BS 3 Outside Old Gym
Lab Sample ID: 420-193868-16

Date Sampled: 03/23/2021 0417
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0529		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Faculty BS Outside Old Gym
Lab Sample ID: 420-193868-17

Date Sampled: 03/23/2021 0420
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0531		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	7.29	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Outside Old Gym BF
Lab Sample ID: 420-193868-18

Date Sampled: 03/23/2021 0420
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0533		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Outside Old Gym Girls BS 1
Lab Sample ID: 420-193868-19

Date Sampled: 03/23/2021 0421
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0535	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Outside Old Gym Girls BS 2
Lab Sample ID: 420-193868-20

Date Sampled: 03/23/2021 0421
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0538	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	10.4	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Outside Old Gym Girls BS 3
Lab Sample ID: 420-193868-21

Date Sampled: 03/23/2021 0421
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0540		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Boys Room by 118 BS 1
Lab Sample ID: 420-193868-22

Date Sampled: 03/23/2021 0425
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0548	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Boys Room by 118 BS 2
Lab Sample ID: 420-193868-23

Date Sampled: 03/23/2021 0425
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0555	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	10.8	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: BF by 118
Lab Sample ID: 420-193868-24

Date Sampled: 03/23/2021 0425
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0557	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Faculty BS by 118
Lab Sample ID: 420-193868-25

Date Sampled: 03/23/2021 0426
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0559	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Girls Room by 118 BS 1
Lab Sample ID: 420-193868-26

Date Sampled: 03/23/2021 0428
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0602		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Girls Room by 118 BS 2
Lab Sample ID: 420-193868-27

Date Sampled: 03/23/2021 0428
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 2219		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 1538		
Pb	46.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Nurse BS
Lab Sample ID: 420-193868-28

Date Sampled: 03/23/2021 0431
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0604		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Nurse NS
Lab Sample ID: 420-193868-29

Date Sampled: 03/23/2021 0431
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0606		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	5.81	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Nurse KS
Lab Sample ID: 420-193868-30

Date Sampled: 03/23/2021 0431
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0608	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	6.56	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Stage Left BS
Lab Sample ID: 420-193868-31

Date Sampled: 03/23/2021 0435
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0610		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Stage BF
Lab Sample ID: 420-193868-32

Date Sampled: 03/23/2021 0435
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0615		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Stage Right BS
Lab Sample ID: 420-193868-33

Date Sampled: 03/23/2021 0435
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0621		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Band Room CS
Lab Sample ID: 420-193868-34

Date Sampled: 03/23/2021 0428
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0623		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.79	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: South Cafeteria BF
Lab Sample ID: 420-193868-35

Date Sampled: 03/23/2021 0439
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0626		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: **Serving Area HWS**
Lab Sample ID: **420-193868-36**

Date Sampled: 03/23/2021 0440
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution	
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021	2222		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	1538		
Pb	40.9	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Serving Area Prep Sink
Lab Sample ID: 420-193868-37

Date Sampled: 03/23/2021 0440
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021	2225	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	1538	
Pb	41.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Kitchen Prep Sink
Lab Sample ID: 420-193868-38

Date Sampled: 03/23/2021 0442
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0628	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	9.39	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Dishwasher Room Sink 1
Lab Sample ID: 420-193868-39

Date Sampled: 03/23/2021 0443
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021	2229	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	1538	
Pb	10.1	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Dishwasher Room Sink 2
Lab Sample ID: 420-193868-40

Date Sampled: 03/23/2021 0443
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0630		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	23.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Dishwasher Room Sink 3
Lab Sample ID: 420-193868-41

Date Sampled: 03/23/2021 0443
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0632	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	4.71	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Kitchen Pot Filler
Lab Sample ID: 420-193868-42

Date Sampled: 03/23/2021 0445
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0641	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	8.05	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Kitchen HWS
Lab Sample ID: 420-193868-43

Date Sampled: 03/23/2021 0445
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0647	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	3.14	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Kitchen Single Sink
Lab Sample ID: 420-193868-44

Date Sampled: 03/23/2021 0446
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021	2232	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	1538	
Pb	28.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Kitchen KS 1
Lab Sample ID: 420-193868-45

Date Sampled: 03/23/2021 0447
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0650	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	7.91	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Kitchen KS 2
Lab Sample ID: 420-193868-46

Date Sampled: 03/23/2021 0447
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0652	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	4.01	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Kitchen Left BS
Lab Sample ID: 420-193868-47

Date Sampled: 03/23/2021 0448
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0654		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.38	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Kitchen Right BS
Lab Sample ID: 420-193868-48

Date Sampled: 03/23/2021 0448
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0656		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.06	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: North Cafe BF
Lab Sample ID: 420-193868-49

Date Sampled: 03/23/2021 0451
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0658	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: New Gym Boys BS 1
Lab Sample ID: 420-193868-50

Date Sampled: 03/23/2021 0453
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0700		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: New Gym Boys BS 2
Lab Sample ID: 420-193868-51

Date Sampled: 03/23/2021 0453
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0703		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.74	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: New Gym Boys BS 3
Lab Sample ID: 420-193868-52

Date Sampled: 03/23/2021 0453
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0707	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	1.09	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: New Gym Girls BS 1
Lab Sample ID: 420-193868-53

Date Sampled: 03/23/2021 0455
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0714		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: New Gym Girls BS 2
Lab Sample ID: 420-193868-54

Date Sampled: 03/23/2021 0455
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0716		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	2.10	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: New Gym Girls BS 3
Lab Sample ID: 420-193868-55

Date Sampled: 03/23/2021 0455
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0718		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Phys Ed Office BS
Lab Sample ID: 420-193868-56

Date Sampled: 03/23/2021 0458
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0720	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	2.85	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Training Room CS
Lab Sample ID: 420-193868-57

Date Sampled: 03/23/2021 0500
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0722		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.54	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Training Room Hose
Lab Sample ID: 420-193868-58

Date Sampled: 03/23/2021 0500
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 2235		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 1538		
Pb	1.76	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: New Gym Boys Locker Room BS 1
Lab Sample ID: 420-193868-59

Date Sampled: 03/23/2021 0502
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0724		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.57	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: New Gym Boys Locker Room BS 3
Lab Sample ID: 420-193868-60

Date Sampled: 03/23/2021 0502
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0727		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: New Gym Mens Coaches BS
Lab Sample ID: 420-193868-61

Date Sampled: 03/23/2021 0503
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0729		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: New Gym BF
Lab Sample ID: 420-193868-62

Date Sampled: 03/23/2021 0504
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0742		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: New Gym Womens Coaches BS
Lab Sample ID: 420-193868-63

Date Sampled: 03/23/2021 0505
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0744		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: New Gym Girls Locker Room BS 3
Lab Sample ID: 420-193868-64

Date Sampled: 03/23/2021 0505
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0746		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Athletic Director KS
Lab Sample ID: 420-193868-65

Date Sampled: 03/23/2021 0508
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0748	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	2.14	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: By 165 Mens BS 1
Lab Sample ID: 420-193868-66

Date Sampled: 03/23/2021 0511
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0751		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: By 165 Mens BS 2
Lab Sample ID: 420-193868-67

Date Sampled: 03/23/2021 0511
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0753		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	8.17	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: By 165 Girls BS 1
Lab Sample ID: 420-193868-68

Date Sampled: 03/23/2021 0513
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0755		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: By 165 Girls BS
Lab Sample ID: 420-193868-69

Date Sampled: 03/23/2021 0513
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 0757	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	1.83	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: By 165 DF
Lab Sample ID: 420-193868-70

Date Sampled: 03/23/2021 0513
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 0759		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: 164 CS
Lab Sample ID: 420-193868-71

Date Sampled: 03/23/2021 0514
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/16/2021 1515	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	13.0	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Womens Faculty BS by 163
Lab Sample ID: 420-193868-72

Date Sampled: 03/23/2021 0516
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/16/2021 1519	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	4.95	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Mens Faculty BS by 163
Lab Sample ID: 420-193868-73

Date Sampled: 03/23/2021 0516
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/16/2021 1521	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	4.03	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: By 65 Boys BS 1
Lab Sample ID: 420-193868-74

Date Sampled: 03/23/2021 0519
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1523		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: By 65 Boys BS 2
Lab Sample ID: 420-193868-75

Date Sampled: 03/23/2021 0519
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021	1526	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	0830	
Pb	1.88	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: By 65 Girls BS 1
Lab Sample ID: 420-193868-76

Date Sampled: 03/23/2021 0521
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021 2238		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 1538		
Pb	19.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: By 65 Girls BS 2
Lab Sample ID: 420-193868-77

Date Sampled: 03/23/2021 0521
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/16/2021 1528	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: By 65 BF
Lab Sample ID: 420-193868-78

Date Sampled: 03/23/2021 0522
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1530		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Special Ed CS
Lab Sample ID: 420-193868-79

Date Sampled: 03/23/2021 0526
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021	1532	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	0830	
Pb	13.1	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Faculty Room KS
Lab Sample ID: 420-193868-80

Date Sampled: 03/23/2021 0526
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1539		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	8.88	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Faculty Utility Sink
Lab Sample ID: 420-193868-81

Date Sampled: 03/23/2021 0528
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021	1541	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	0830	
Pb	6.14	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Faculty Room Womans BS
Lab Sample ID: 420-193868-82

Date Sampled: 03/23/2021 0528
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1550		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Faculty Room Mens BS
Lab Sample ID: 420-193868-83

Date Sampled: 03/23/2021 0528
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1552		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Boys Old Gym Locker Room BS
Lab Sample ID: 420-193868-84

Date Sampled: 03/23/2021 0531
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1554		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	4.84	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Boys Swim Coach BS
Lab Sample ID: 420-193868-85

Date Sampled: 03/23/2021 0533
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021	2247	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	1538	
Pb	25.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Boys Swim Locker Room BS
Lab Sample ID: 420-193868-86

Date Sampled: 03/23/2021 0534
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1556		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Girls Swim Locker Room BS
Lab Sample ID: 420-193868-87

Date Sampled: 03/23/2021 0535
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/16/2021 1558	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	3.11	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Girls Swim Coach BS
Lab Sample ID: 420-193868-88

Date Sampled: 03/23/2021 0537
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021	1605	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	0830	
Pb	4.82	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Girls Old Gym Locker Room BS
Lab Sample ID: 420-193868-89

Date Sampled: 03/23/2021 0538
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/16/2021 1607	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	7.95	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Library KS
Lab Sample ID: 420-193868-90

Date Sampled: 03/23/2021 0541
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021	1609	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	0830	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: BF by 142
Lab Sample ID: 420-193868-91

Date Sampled: 03/23/2021 0543
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1611		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: 143 CS
Lab Sample ID: 420-193868-92

Date Sampled: 03/23/2021 0544
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021	1616	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	0830	
Pb	1.48	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Ag Shop CS 1
Lab Sample ID: 420-193868-93

Date Sampled: 03/23/2021 0545
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/16/2021 1618	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Ag Shop CS 2
Lab Sample ID: 420-193868-94

Date Sampled: 03/23/2021 0545
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1620		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Ag Shop Single Sink
Lab Sample ID: 420-193868-95

Date Sampled: 03/23/2021 0545
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1622		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Custodial Break Room KS
Lab Sample ID: 420-193868-96

Date Sampled: 03/23/2021 0548
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021	1625	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	0830	
Pb	1.29	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Mens BS by 138
Lab Sample ID: 420-193868-97

Date Sampled: 03/23/2021 0550
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1631		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	13.4	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Womans BS 1 by 138
Lab Sample ID: 420-193868-98

Date Sampled: 03/23/2021 0550
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/16/2021 1633	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	5.40	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Womans BS 2 by 138
Lab Sample ID: 420-193868-99

Date Sampled: 03/23/2021 0550
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/27/2021 0721		
Prep Method: 200.7/200.8			Date Prepared: 04/15/2021 1138		
Pb	34.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Conference Room KS
Lab Sample ID: 420-193868-100

Date Sampled: 03/23/2021 0554
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021	1636	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	0830	
Pb	6.64	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Girls BS 1 by 234
Lab Sample ID: 420-193868-101

Date Sampled: 03/23/2021 0557
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/15/2021 2250	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 1538	
Pb	6.56	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Girls BS 2 by 234
Lab Sample ID: 420-193868-102

Date Sampled: 03/23/2021 0557
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/15/2021	2253	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	1538	
Pb	45.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Girls BS 3 by 234
Lab Sample ID: 420-193868-103

Date Sampled: 03/23/2021 0557
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1638		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	14.3	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Boys BS 1 by 234
Lab Sample ID: 420-193868-104

Date Sampled: 03/23/2021 0559
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021	1646	
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021	0830	
Pb	35.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Boys BS 2 by 234
Lab Sample ID: 420-193868-105

Date Sampled: 03/23/2021 0559
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/16/2021 1649	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	3.60	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Boys BS 3 by 234
Lab Sample ID: 420-193868-106

Date Sampled: 03/23/2021 0559
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/16/2021 1651	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	2.03	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Faculty BS by 236A
Lab Sample ID: 420-193868-107

Date Sampled: 03/23/2021 0602
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1657		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Boys BS by 218
Lab Sample ID: 420-193868-108

Date Sampled: 03/23/2021 0606
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1700		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Faculty BS by 218
Lab Sample ID: 420-193868-109

Date Sampled: 03/23/2021 0606
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1702		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: BF by 218
Lab Sample ID: 420-193868-110

Date Sampled: 03/23/2021 0607
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1704		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Girls BS 1 by 218
Lab Sample ID: 420-193868-111

Date Sampled: 03/23/2021 0608
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 04/16/2021 1706		
Prep Method: 200.7/200.8			Date Prepared: 04/13/2021 0830		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-193868-1
Sdg Number: Warwick High School

Client Sample ID: Girls BS 2 by 218
Lab Sample ID: 420-193868-112

Date Sampled: 03/23/2021 0608
Date Received: 03/24/2021 1041
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	04/16/2021 1711	
Prep Method: 200.7/200.8			Date Prepared:	04/13/2021 0830	
Pb	4.50	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:
Sdg Number: Warwick High School

Lab Section	Qualifier	Description
Metals	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Warwick High School

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Setttable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

Definitions and Glossary

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Warwick High School

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

EnviroTest Laboratories, LLC

315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information Client Contact: Kevin Flynn	Sampler: J DeGraw Phone: 845-781-4887	Lab PM: E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 193868 1 of 8
---	--	--	--	--

Company: Orange-Ulster BOCES	Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924 Phone: 845-781-4887 Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	Due Date Requested: Standard Turn-Around TAT Requested (days): PO #: PWS #: Project #: Additional Contacts:	Analysis Requested	Page: Page 1 of 1	Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA - Sodium Sulfite N - None O - MCAA P - Other (specify) Other: D-Nitric Acid Upon Receipt Preservation verified: Y / N
---------------------------------	---	---	---------------------------	----------------------	--

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/soil)	Field Filtered Sample (Yes or No)	Performs MS/MS (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
3/23/21	4:01	Loading Dock BS		G	DW				1		
3/23/21	4:04	Office KS		G	DW				1		
3/23/21	4:05	Office Left BS		G	DW				1		
3/23/21	4:05	Office Right BS		G	DW				1		
3/23/21	4:06	Mens BS by Elevator		G	DW				1		
3/23/21	4:06	Ladies BS by Elevator		G	DW				1		
3/23/21	4:08	Guidance Hall Way Girls BS 1		G	DW				1		
3/23/21	4:08	Guidance Hall Way Girls BS 2		G	DW				1		
3/23/21	4:08	Guidance Hall Way Girls BS 3		G	DW				1		
3/23/21	4:11	Guidance Hall Way Boys BS 1		G	DW				1		
3/23/21	4:11	Guidance Hall Way Boys BS 2		G	DW				1		
3/23/21	4:11	Guidance Hall Way Boys BS 3		G	DW				1		
3/23/21	4:15	Guidnce BS		G	DW				1		
3/23/21	4:17	Boys BS 1 Outside Old Gym		G	DW				1		
3/23/21	4:17	Boys BS 2 Outside Old Gym		G	DW				1		



420-193868-B-1
Loading Dock BS
Date Sampled: 3/23/2021 420-1652360

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle	P	Container Type			
Preservation/Added Upon Receipt:	Manufacturer/Lot #:	Date:	Time:	Sample # (s):	
Relinquished by: <i>[Signature]</i>	Date/Time: 3/24/21	Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 3/24/21 10:41	Company: <i>[Signature]</i>
Relinquished by: <i>[Signature]</i>	Date/Time: 3/24/21 10:41	Company: <i>[Signature]</i>	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
ICE Present: <i>N</i>	Custody Seal No.:	Custody Seals Intact: Δ	Cooler Temperature(s) °C/IR GUN #: 17.8°C		

EnviroTest Laboratories, LLC

315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information	Sampler: J DeGraw	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 193868 2 of 8
	Client Contact: Kevin Flynn	Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	

Company: Orange-Ulster BOCES	Due Date Requested: Standard Turn-Around	Analysis Requested			Page: Page 1 of 1		
Address: 53 Gibson Road	TAT Requested (days):	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)
City: Goshen	PO #:						
State, Zip: NY, 10924	PWS #:						
Phone: 845-781-4887	Project #:						
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	Additional Contacts:				Other: D-Nitric Acid		
Project Name: Warwick VCSD					Upon Receipt Preservation verified: Y / N		
Warwick High School							

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
				Preservation Code:					D		
3/23/21	4:17	Boys BS 3 Outside Old Gym		G	DW				1	1	
3/23/21	4:20	Faculty BS Outside Old Gym		G	DW				1	1	
3/23/21	4:20	Outside Old Gym BF		G	DW				1	1	
3/23/21	4:21	Outside Old Gym Girls BS 1		G	DW				1	1	
3/23/21	4:21	Outside Old Gym Girls BS 2		G	DW				1	1	
3/23/21	4:21	Outside Old Gym Girls BS 3		G	DW				1	1	
3/23/21	4:25	Boys Room by 118 BS 1		G	DW				1	1	
3/23/21	4:25	Boys Room by 118 BS 2		G	DW				1	1	
3/23/21	4:25	BF by 118		G	DW				1	1	
3/23/21	4:26	Faculty BS by 118		G	DW				1	1	
3/23/21	4:28	Girls Rom by 118 BS 1		G	DW				1	1	
3/23/21	4:28	Girls Rom by 118 BS 2		G	DW				1	1	
3/23/21	4:31	Nurse BS		G	DW				1	1	
3/23/21	4:31	Nurse NS		G	DW				1	1	
3/23/21	4:31	Nurse KS		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle

Preservation Added Upon Receipt:	Manufacturer/lot #:	Date:	Time:	Sample # (s):	Container Type
Relinquished by: <i>[Signature]</i>	Date/Time: 3/24/21	Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 3/24/21 1041	Company: <i>[Signature]</i>
Relinquished by: <i>[Signature]</i>	Date/Time: 3/24/21 1019	Company: 4	Received by:	Date/Time:	Company:
Relinquished by: <i>[Signature]</i>	Date/Time:	Company:	Received by:	Date/Time:	Company:

ICE Present: Custody Seal No.: _____ Custody Seals Intact: Cooler Temperature(s) °C/IR GUN #: 17.8°C

EnviroTest Laboratories, LLC

315 Fullerton Avenue
 Newburgh, NY 12550
 Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information	Sampler: J DeGraw	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 193868 3 of 8
	Client Contact: Kevin Flynn	Phone: 845-781-4887		

Company: Orange-Ulster BOCES	Due Date Requested: Standard Turn-Around	Analysis Requested				Page: Page 1 of 1
Address: 53 Gibson Road	TAT Requested (days):	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers
City: Goshen	PO #:					
State, Zip: NY, 10924	PWS #:					
Phone: 845-781-4887	Project #:					
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	Additional Contacts:					Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA - Sodium Sulfitte N - None O - MCAA P - Other (specify) M Other: D-Nitric Acid Upon Receipt Preservation verified: Y / N
Project Name: Warwick VCSD	Warwick High School					

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
				Preservation Code:							
3/23/21	4:35	Stage Left BS		G	DW				1	1	
3/23/21	4:35	Stage BF		G	DW				1	1	
3/23/21	4:35	Stage Right BS		G	DW				1	1	
3/23/21	4:28	Band Room CS		G	DW				1	1	
3/23/21	4:39	South Cafeteria BF		G	DW				1	1	
3/23/21	4:40	Serving Area HWS		G	DW				1	1	
3/23/21	4:40	Serving Area Prep Sink		G	DW				1	1	
3/23/21	4:42	Kitchen Prep Sink		G	DW				1	1	
3/23/21	4:43	Dishwasher Room Sink 1		G	DW				1	1	
3/23/21	4:43	Dishwasher Room Sink 2		G	DW				1	1	
3/23/21	4:43	Dishwasher Room Sink 3		G	DW				1	1	
3/23/21	4:45	Kitchen Pot Filler		G	DW				1	1	
3/23/21	4:45	Kitchen HWS		G	DW				1	1	
3/23/21	4:46	Kitchen Single Sink		G	DW				1	1	
3/23/21	4:47	Kitchen KS 1		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle

Preservation Added Upon Receipt: _____ Manufacturer/Lot #: _____ Date: _____ Time: _____ Sample # (s): _____

Relinquished by: <i>[Signature]</i>	Date/Time: 3/24/21	Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 3/24/21 10:41	Company: <i>[Signature]</i>
Relinquished by: <i>[Signature]</i>	Date/Time: 3/24/21 10:14	Company: 11	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:

ICE Present: *No* Custody Seal No.: _____ Custody Seals Intact: Δ Cooler Temperature(s) °C/IR GUN #: *17.8°C*

EnviroTest Laboratories, LLC

315 Fullerton Avenue
 Newburgh, NY 12550
 Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information Client Contact: Kevin Flynn	Sampler: J DeGraw	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 193868 HCF8
	Phone: 845-781-4887	E-Mail: joseph.russo@oubores.org Halina.redner@oubores.org Maureen.doherty@oubores.org		

Company: Orange-Ulster BOCES	Due Date Requested: Standard Turn-Around	Analysis Requested				Page: Page 1 of 1
Address: 53 Gibson Road	TAT Requested (days):					
City: Goshen	PO #:	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers
State, Zip: NY, 10924						
Phone: 845-781-4887	Project #:	Matrix (DW= drinking water, W=water, S=solid, O=waste/soil)	Other:	Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate		
Email: joseph.russo@oubores.org Halina.redner@oubores.org Maureen.doherty@oubores.org				Additional Contacts:	L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)	
Project Name: Warwick VCSD Warwick High School			Other: D-Nitric Acid Upon Receipt Preservation verified: Y / N			

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=Comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/soil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
3/23/21	4:47	Kitchen KS 2		G	DW				1	1	
3/23/21	4:48	Kitchen Left BS		G	DW				1	1	
3/23/21	4:48	Kitchen Right BS		G	DW				1	1	
3/23/21	4:51	North Café BF		G	DW				1	1	
3/23/21	4:53	New Gym Boys BS 1		G	DW				1	1	
3/23/21	4:53	New Gym Boys BS 2		G	DW				1	1	
3/23/21	4:53	New Gym Boys BS 3		G	DW				1	1	
3/23/21	4:55	New Gym Girls BS 1		G	DW				1	1	
3/23/21	4:55	New Gym Girls BS 2		G	DW				1	1	
3/23/21	4:55	New Gym Girls BS 3		G	DW				1	1	
3/23/21	4:58	Phys ED Office BS		G	DW				1	1	
3/23/21	5:00	Training Room CS		G	DW				1	1	
3/23/21	5:00	Training Room Hose		G	DW				1	1	
3/23/21	5:02	New Gym Boys Locker Room BS 1		G	DW				1	1	
3/23/21	5:02	New Gym Boys Locker Room BS 3		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		Preservation Added Upon Receipt:		Manufacturer/lot #:		Date:		Time:		Sample # (s):		Container Type	
Relinquished by: <i>[Signature]</i>	Date/Time: 3/24/21	Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 3/24/21	1015	Company:							
Relinquished by: <i>[Signature]</i>	Date/Time: 3/29/21	Company:	Received by:	Date/Time:	Company:								
Relinquished by: <i>[Signature]</i>	Date/Time:	Company:	Received by:	Date/Time:	Company:								
ICE Present: <input checked="" type="checkbox"/>		Custody Seal No.:		Custody Seals Intact: <input checked="" type="checkbox"/>		Cooler Temperature(s) °C/IR GUN #: 17.8°C							

EnviroTest Laboratories, LLC

315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information		Sampler: J DeGraw	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 193868 5 of 8
Client Contact: Kevin Flynn		Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		

Company: Orange-Ulster BOCES		Analysis Requested			Page: Page 1 of 1			
Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Preservation Codes: A - HCL L - EDA M B - NaOH - Sodium Sulfitte C - Zn Acetate N - None D - Nitric Acid O - MCAA E - H2SO4 F - MeOH G - NH4CL P - Other (specify) H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate
City: Goshen		TAT Requested (days):						
State, Zip: NY, 10924		PO #:						
Phone: 845-781-4887		PWS #:						
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		Project #:	Other: D-Nitric Acid					
Project Name: Warwick VCSD		Additional Contacts:	Upon Receipt Preservation verified: Y / N					
Warwick High School								

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
3/23/21	5:03	New Gym Mens Coaches BS		G	DW				1	1	
3/23/21	5:04	New Gym BF		G	DW				1	1	
3/23/21	5:05	New Gym Women's Coaches BS		G	DW				1	1	
3/23/21	5:05	New Gym Girl's locker Room BS 3		G	DW				1	1	
3/23/21	5:08	Athletic Director KS		G	DW				1	1	
3/23/21	5:11	By 165 Mens BS 1		G	DW				1	1	
3/23/21	5:11	By 165 Mens BS 2		G	DW				1	1	
3/23/21	5:13	By 165 Girls BS 1		G	DW				1	1	
3/23/21	5:13	By 165 Girls BS		G	DW				1	1	
3/23/21	5:13	By 165 BF		G	DW				1	1	
3/23/21	5:14	164 CS		G	DW				1	1	
3/23/21	5:16	Women's Faculty BS by 163		G	DW				1	1	
3/23/21	5:16	Men's Faculty BS by 163		G	DW				1	1	
3/23/21	5:19	By 65 Boys BS 1		G	DW				1	1	
3/23/21	5:19	By 65 Boys BS 2		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		Manufacturer/Lot #:		Date:	Time:	Sample # (s):	Container Type
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:		
<i>[Signature]</i>	3/24/21	OUBOCES	<i>[Signature]</i>	3/24/21 10:41	OUBOCES		
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:		
<i>[Signature]</i>	3/23/21	OUBOCES	<i>[Signature]</i>				
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:		
<i>[Signature]</i>							

ICE Present: Custody Seal No.: _____ Custody Seals Intact: Cooler Temperature(s) °C/IR GUN #: **17.8°C**

EnviroTest Laboratories, LLC

315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information		Sampler: J DeGraw	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 193868 <i>6 of 8</i>
Client Contact: Kevin Flynn		Phone: 845-781-4887	E-Mail: joseph.russo@oubores.org Halina.redner@oubores.org Maureen.doherty@oubores.org		

Company: Orange-Ulster BOCES		Due Date Requested: Standard Turn-Around		Analysis Requested		Page: Page 1 of 1	
Address: 53 Gibson Road		TAT Requested (days):				Preservation Codes:	
City: Goshen		PO #:		A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)		Other: D-Nitric Acid	
State, Zip: NY, 10924		PWS #:				Upon Receipt Preservation verified: Y / N	
Phone: 845-781-4887		Project #:					
Email: joseph.russo@oubores.org Halina.redner@oubores.org Maureen.doherty@oubores.org		Additional Contacts:					
Project Name: Warwick VCSD Warwick High School							

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
				Preservation Code:					D		
3/23/21	5:21	By 65 Girls BS 1		G	DW				1	1	
3/23/21	5:21	By 65 Girls BS 2		G	DW				1	1	
3/23/21	5:22	By 65 BF		G	DW				1	1	
3/23/21	5:26	Special Ed CS		G	DW				1	1	
3/23/21	5:26	Faculty Room KS		G	DW				1	1	
3/23/21	5:28	Faculty Utility Sink		G	DW				1	1	
3/23/21	5:28	Faculty Room Womans BS		G	DW				1	1	
3/23/21	5:28	Faculty Room Mens BS		G	DW				1	1	
3/23/21	5:31	Boys Old Gym Locker Room BS		G	DW				1	1	
3/23/21	5:33	Boys Swim Coach BS		G	DW				1	1	
3/23/21	5:34	Boys Swim Locker Room BS		G	DW				1	1	
3/23/21	5:35	Girls Swim Locker Room BS		G	DW				1	1	
3/23/21	5:37	Girls Swim Coach BS		G	DW				1	1	
3/23/21	5:38	Girl's Old Gym Locker Room BS		G	DW				1	1	
3/23/21	5:41	Library KS		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		P		Container Type	
Preservation Added Upon Receipt:		Manufacturer/lot #:		Date:	
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
<i>J. Russo</i>	3/24/21	OUBOCES	<i>Halina Redner</i>	3/24/21 10:48	ETL
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
<i>Maureen Doherty</i>	3/24/21	OUBOCES	<i>Halina Redner</i>		
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:

ICE Present: *No* Custody Seal No.: _____ Custody Seals Intact: Δ Cooler Temperature(s) °C/IR GUN #: *17.8°C*

EnviroTest Laboratories, LLC

315 Fullerton Avenue
 Newburgh, NY 12550
 Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information		Sampler: J DeGraw	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 193868 <i>7 of 8</i>
Client Contact: Kevin Flynn		Phone: 845-781-4887	E-Mail: joseph.russo@oubores.org Halina.redner@oubores.org Maureen.doherty@oubores.org		

Company: Orange-Ulster BOCES		Analysis Requested			Page: Page 1 of 1			
Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers:	Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)
City: Goshen		TAT Requested (days):						
State, Zip: NY, 10924		PO #:						
Phone: 845-781-4887		PWS #:						
Email: joseph.russo@oubores.org Maureen.doherty@oubores.org		Project #:						
Project Name: Warwick VCSD		Additional Contacts:			Other: D-Nitric Acid			
Warwick High School					Upon Receipt Preservation verified: Y / N			

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/soil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
3/23/21	5:43	BF by 142		G	DW				1	1	
3/23/21	5:44	143 CS		G	DW				1	1	
3/23/21	5:45	Ag Shop CS 1		G	DW				1	1	
3/23/21	5:45	Ag Shop CS 2		G	DW				1	1	
3/23/21	5:45	Ag Shop Single Sink		G	DW				1	1	
3/23/21	5:48	Custodial Bareak Room KS		G	DW				1	1	
3/23/21	5:50	Mens BS by 138		G	DW				1	1	
3/23/21	5:50	Woman's BS 1 by 138		G	DW				1	1	
3/23/21	5:50	Woman's BS 2 by 138		G	DW				1	1	
3/23/21	5:54	Conference Room KS		G	DW				1	1	
3/23/21	5:57	Girls BS 1 by 234		G	DW				1	1	
3/23/21	5:57	Girls BS 2 by 234		G	DW				1	1	
3/23/21	5:57	Girls BS 3 by 234		G	DW				1	1	
3/23/21	5:59	Boys BS 1 by 234		G	DW				1	1	
3/23/21	5:59	Boys BS 2 by 234		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		Manufacturer/lot #:		Date:	Time:	Sample # (s):	Container Type
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:		
<i>[Signature]</i>	3/24/21	OUBOCES	<i>[Signature]</i>	3/24/21 10:41			
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:		
<i>[Signature]</i>	3/24/21 10:14	21					
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:		

ICE Present: *No* Custody Seal No.: _____ Custody Seals Intact: Δ Cooler Temperature(s) °C/IR GUN #: *17.8°C*

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Orange-Ulster BOCES

Job Number: 420-193868-1
SDG Number: Warwick High School

Login Number: 193868

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	17.8 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	True	
If false, was sample received on ice within 6 hours of collection.	NA	
Based on above criteria cooler temperature is acceptable.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	